

- xref's loaded in file

1. CONTRACTOR IS RESPONSIBLE FOR ALL SETTING OUT AND MUST CHECK DIMENSIONS ON SITE BEFORE WORK IS PUT IN HAND
2. WRITTEN DIMENSIONS ONLY TO BE TAKEN THIS DRAWING MUST NOT BE SCALED
3. ARCHITECT TO BE IMMEDIATELY NOTIFIED OF SUSPECTED OMISSIONS OR DISCREPANCIES

REVISIONS	
ISSUED FOR CONSTRUCTION	17.05.16 rkc
C6/Gen revs	24.05.16 rkc
C6/Bathrooms revd	20.06.16 rkc
C6/Roofs changed spec e	06.07.16 rkc
C6/Int revd	14.07.16 rkc
C6/markup revs	22.07.16 rkc

Wall Types Legend

Type A: External Wall.
102.5mm stretcher bond facing brickwork with 10mm mortar joints, 130mm full fill blown mineral wool fibre insulation, 100mm stretcher bond light weight concrete blockwork with 10mm mortar joints, finished internally with 15mm SoundBloc plasterboard on 10mm dabs

Type B: Internal Party Wall.
100mm stretcher bond lightweight blockwork with 10mm mortar joints with bed reinforcement, 100mm full fill blown mineral wool fibre insulation, 100mm stretcher bond light weight concrete blockwork with 10mm mortar joints. Each side internally finished with 15mm SoundBloc plasterboard on 10mm dabs

Type C: Internal Party Wall.
100mm stretcher bond lightweight blockwork with 10mm mortar joints, 100mm full fill blown mineral wool fibre insulation, 100mm stretcher bond light weight concrete blockwork with 10mm mortar joints. Each side internally finished with 15mm SoundBloc plasterboard on 10mm dabs

Type D: Internal Timber Stud Wall.
63mm x 48mm timber studs at 400mmc with 15mm SoundBloc each side

Type E: Internal Timber Stud Wall to bathrooms.
63mm x 48mm timber studs at 400mmc with 1 layer 12mm WBP ply to the "wet" side and 15mm SoundBloc each side

Type G: Internal Services Boxing Stud Wall.
63mm x 48mm timber studs at 400mmc with 1 layer 12mm WBP ply to the "wet" side and 15mm SoundBloc one side

Type H: Internal Timber Stud Wall.
63mm x 48mm timber studs at 400mmc with 1 layer 12mm WBP ply to the "wet" side and 15mm SoundBloc one side

Opening Reference Legend

Denotes opening type: Door, Window, Screen

Denotes room number

Denotes opening n°

Denotes floor level and unit/plot reference n°

ISSUED FOR CONSTRUCTION

RDJW

ARCHITECTS



RDJW ARCHITECTS LIMITED
QUIN HOUSE . 9-11 EAST PARK CRAWLEY . WEST SUSSEX . RH10 6AN
TEL: 01293 404300 . FAX: 01293 404299
EMAIL: info@rdjwarchitects.co.uk
WEBSITE: www.rdjwarchitects.co.uk

PROJECT
Housing Development
Springfield Hospital
Hebdon Road
Tooting

Proposed Type 1
4 Bed End of Terrace
General Arrangement Plans

DATE	30.09.15	SCALE	1:50 @ A1
DRAWN	RKC	DRG. NO.	4720-112
CHECKED		REV.	C6

